



## REQUIREMENTS FOR AN ELECTRICAL INSPECTION

**The following scenarios require a wiring approval from a certified Electrical Inspector:**

- Meter and/or service tampering or involved in theft of service
- Meter booted or disconnected for a period of more than one year
- Meter removed for a period of more than one year
- Meter and service removed for a period of more than one year
- Service line cut at pole for a period of more than one year
- Replacing a meter base
- Changing a meter location
- Upgrading service (example: 100 to 200 amp)
- Changing from fuses to breakers (which requires service panel to be replaced)
- Replacing a main breaker (in the service panel inside of the building)
- Replacing a Main Disconnecting Means (main switch or transfer switch)
- Changing service mast
- Changing from overhead to underground
- Renewable energy (Distributed Generation) installations
- Transfer installation for generator (emergency / standby) installation
- Damage to meter base and/or service entrance cable
- Anytime there is a fire in a premise that is electrically related
- Main breaker panel, fuse box, or meter base was under water
- Replacement of jaws in the meter socket (due to deterioration)
- In addition to the scenarios above, anytime a component of the electrical service is installed/replaced/removed
- Any other instance where, in the judgement of the Company, a wiring approval is necessary to ensure safe energization of the customer's electric service