



**NOTES**

1. THE CUSTOMER SHALL PROVIDE A TRENCH THAT IS WELL TAMPED AND FIRM.
2. WHEN THE CUSTOMER IS REQUIRED TO INSTALL CABLE, PROVIDE AMPLE CABLE SLACK TO ALLOW FOR CABLE MOVEMENT. THE COMPANY RECOMMENDS LEAVING LOOPS IN THE METER SOCKET.
3. THE CUSTOMER SHALL PROVIDE GROUND MOVEMENT PROTECTION PER 2023 NEC 300.5(J) TO PREVENT DAMAGE DUE TO SETTLEMENT OR MOVEMENT, INCLUDING FROST HEAVE. THE COMPANY RECOMMENDS THAT THE CUSTOMER USE A SLIP-JOINT CONDUIT PRODUCT. ANY SLIP-JOINT DESIGN THAT MEETS THE AFOREMENTIONED NEC CODE AND MADE OF SCHEDULE 80 PVC IS ACCEPTABLE.
4. CUSTOMER SHALL PROVIDE CONDUIT STRAP ON EITHER ENDS OF THE GROUND MOVEMENT PROTECTION (SLIP-JOINT) PER NEC OR DLC WILL NOT ENERGIZE OR PERFORM WORK.

**TYPICAL UNDERGROUND SERVICE LATERAL  
EXPANSION FITTING INSTALLATION**